



Certificate of Compliance

Certificate: 70143505

Master Contract: 150815 (047307_S_000)

Project: 70143505

Date Issued: 2018-02-15

Issued to: Wintriss Controls Group LLC
100 Discovery Way, Unit 110
Acton, Massachusetts 01720
USA
Attention: Luis Travassos

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: *Reddiprasad Cheekoori*
Reddiprasad Cheekoori

PRODUCTS

CLASS - C225206 - PROCESS CONTROL EQUIPMENT

CLASS - C225286 - PROCESS CONTROL EQUIPMENT-Certified to US Standards

Model: SmartPac PRO, Rated 115/230Vac +/- 10%, 50-60Hz, 30 VA (AC version) or 24Vdc +/- 15%, 37 W (DC version); input check rated 12 - 250Vac/dc, 0.25 A; relay contact rated 4.0A max at 30Vdc/240Vac, all other inputs and outputs SELV, Ambient 0 to 50 °C, Installation Category II. Fully enclosed or panel mount versions.

APPLICABLE REQUIREMENTS

- CAN/CSA-C22.2 No. 61010-1-12 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements
- ANSI/UL Std. No. 61010-1 (3rd) - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements



Supplement to Certificate of Compliance

Certificate: 70143505

Master Contract: 150815 (047307_S_000)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70143505	2018-02-15	Evaluation of SmartPac Pro to CSA 61010-1-12, UL 61010-1 3rd and CE Dossier