



# Certificate of Compliance

**Certificate:** 1218760 (LR47307-23)

**Master Contract:** 150815

**Project:** 1562185


**Date Issued:** 2004/07/13

**Issued to:** Honeywell Data Instruments, Inc.  
100 Discovery Way  
Acton, Massachusetts 01720-4483  
USA  
Attention: Mr. Vincent Terrasi

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'*



**Issued by:**

  
Babu Patel P.Eng.

**Authorized by:** Nick Alfano, Operations Manager



## PRODUCTS

**CLASS 3211 87** - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus -  
Certified to US Standards

**CLASS 3211 07** - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

1. DiPro Sensor Interface (DSI), open type, input 120-240V ac, 50/60Hz, 0.5A; Output 24V dc, 0.5A max.

DSI 2 Sensor Interface, open type, Input 120/240V ac, 50/60Hz, 0.5A; Output 24V dc, 0.5A max, 5V, 80mA.

Note: Open type devices are Certified as components for use only with other Certified equipment where the suitability of the combination is determined by the CSA International.

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



**Certificate:** 1218760 (LR47307-23)

**Master Contract:** 150815

**Project:** 1562185

**Date Issued:** 2004/07/13

---

2. Remove Shared Certification.

**APPLICABLE REQUIREMENTS**

CAN/CSA-C22.2 No. 14 - Industrial Control Equipment

UL Std No. 508 - Industrial Control Equipment



## *Supplement to Certificate of Compliance*

**Certificate:** 1218760

**Master Contract:** 150815

*The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
1562185	2004/07/13	Update Report to Include Alternate Construction of DSI-2 Device

### **History**

1218760 Feb. 12, 2002 Covers additional Model DSI-2 and remove Shared Certification.

47307-25 Dec. 19, 1994 Covers the increase of input voltage from 120V ac to 120/240V ac.

47307-23 Nov. 16, 1994 Original report